

Slip Check to AS 4586-2013

Acoustix Forest fx PUR / Silentflor PUR
Batch No: 9A199
Shade: 9970 Dark Industrial Concrete

Report Number: R21094

Report Date: 2 June 2020

Total Number of Pages 2

Accredited for compliance with ISO/IEC 17025 – Testing

The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards

NATA is a signatory to the ILAC Mutual Recognition Arrangement for the mutual recognition of the equivalence of testing, medical testing, calibration and inspection reports

Issued by

Safe Environments Pty Ltd
Unit 4, 40 Bessemer Street
Blacktown NSW 2148
Australia

Prepared for

Polyflor Limited
PO Box 3, Radcliffe New Road, Whitefield
Manchester, M45 7NR
England

Approved by



Dale Rowell
Authorised Signatory

2 June 2020

Test Report No. R21094

Slip Resistance Classification of New Pedestrian Surface Materials

AS 4586-2013 Appendix D (Oil-Wet Inclining Platform Test)

The slip resistance classification has been determined for unused surfaces using specific conditions. Factors such as usage, cleaning systems, applied coatings and patterns of wear may affect the characteristics of the surface after classification. Standards Australia Handbook 198:2014 *Guide to the specification and testing of slip resistance of pedestrian surfaces* provides guidance for the selection of slip resistant pedestrian surfaces classified in accordance with AS 4586-2013. It is recommended that this test report be read in conjunction with AS 4586 and HB 198.

Requested by: Polyflor Limited
Client Address: PO Box 3, Radcliffe New Road, Whitefield
Manchester, M45 7NR
England
Product Manufacturer: Supplied by Polyflor
Product Description: Acoustix Forest fx PUR / Silenflor PUR
Batch No: 9A199
Shade: 9970 Dark Industrial Concrete
Surface Structure: Smooth
Fixed/Unfixed: Unfixed
Joint Width: N/A
Test conducted according to: AS 4586-2013 Appendix D (Incorporating Amendment No. 1)
Location: 4/40 Bessemer Street, Blacktown NSW 2148
Conducted by: Oshi Barkat & Yuliana Vargolomova
Test Shoe Type: Bergmann with Leipzig V73-SP sole form
Date: 2 June 2020
Cleaning: As Received
Air Temperature: 17°C
Displacement Space: Not Measured
Displacement Space Assessment Group: NA

Corrected Mean Overall Acceptance Angle:	15°
Slip Resistance Assessment Group:	R10

This test report shall not be reproduced unless in full, without written approval of Safe Environments Pty Ltd